



Requirements for Authorization of Temporary Power

Prior to notifying the power company to place temporary power on a building, the City of Johns Creek must confirm, through an inspection, that the following conditions have been met:

1. All electrical circuit(s) requested to be energized must be installed according to the latest edition of the National Electric Code as adopted by the Georgia Department of Community Affairs.
2. The meter base, main disconnect and grounding system must be installed according to the latest edition of the National Electric Code as adopted by the Georgia Department of Community Affairs.
3. All panel covers must be in place and secured from accidental contact.
4. The building must be completely secured to prevent entry by unauthorized personnel during non-working hours.
5. The building has been inspected and all deficiencies related to the framing, rough and insulation inspections have been corrected.
6. An Application for Temporary Power must be made with the City of Johns Creek and the appropriate fee paid prior to issuance of authorization. A copy of this form is available on the City's website (Request for Temporary Power).

Temporary Power Authorization will not be issued until **ALL** of these requirements are met.